



ISOTEC

Isotec Safety Entrance
UL Compliant Components

Power Supply:

Altronix P/N: AL600ULX

UL File #S4707

Provides 24 VDC to the entire Safety Entrance System.

Magnetic Lock:

Camden P/N: CX-91S-12-TDS

UL File #S6579

Failsafe 1200lbs. Magnetic Lock 24 VDC

System Override Relay:

IDEC P/N: RH4B-U

UL File #E55996

Cuts power to all 4 magnetic lock when de-energized by Fire Panel, Key Switch and System Override switch.

PLC (Programmable Logic Control):

Panasonic P/N: AFP0RC14RS

UL File #E96300

Provides power to Magnetic locks and other devices using software algorithms based on inputs from system devices.

Emergency Egress Timer Board:

Securitron P/N: XDT-24

UL File #SA6635

Timer Board that when activated will release both exit doors after a 15 or 30 second delay.

Emergency Egress Switch:

Dortronics P/N: N5286

UL File #EX4421

Activates Emergency Egress Timer Board

System Override Key Switch:

Dortronics 5141

UL File #EX4421

De-energizes System Override Relay; or resets Emergency Egress Timer Board.

